



# AGA CERTIFIED PRODUCT

Certificate Holder: **SIT GAS CONTROLS PTY LTD**  
ABN/ACN No. (if applicable): **006 090 357**  
Manufacturer: **SIT S.p.A.**  
Agent (if applicable): **N/A**  
Type of Component: **COMBINATION GAS CONTROL with GAS/AIR RATIO CONTROLLER**

Model No. & Description: **SIT 0.828.XXX (828 NOVAMIX)**  
(Refer [www.aga.asn.au](http://www.aga.asn.au) for more details)  
Rated Working Pressure: **6kPa**  
Working Temperature Range: **0 to 60°C**  
Maximum Flow Rate: **6.5m<sup>3</sup>/h (relative density = 0.6)**

Automatic Shut-off Valves	Gas/Air Pressure Ratio	Regulator	Outlet Pressure
Class 2	3.5:1 to 20:1	Class 2 Grade 20	0.3 – 3.0 kPa 2.0 – 5.0 kPa

*XXX = specific model with unique combination of features within the above ranges;  
Refer to AGA technical specification for details of all features and options*

Relevant Standard(s): **AS 4624 - 2005**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

**This Certificate is issued on the express conditions that:**

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



Reviewing Officer

Certificate Authorised

Certificate first issued: **6 November 1976**

Certificate No: **5182**

This copy valid from: **26 June 2015**

Refer specification issue: **03**