

CERTIFICATE

Certificate holder SIT S.p.a.
Viale dell'Industria 31-33
35129 Padova PD
ITALY

Product Temperature control and limiting devices for heat generating systems

Type, Model 610 AC3 - 650 Delta - 600 AC2

Testing basis DIN EN 14597:2015-02
Certification scheme Temperature control and limiting devices for heat generating systems (2009-01)

Mark of conformity

The logo consists of a blue circle with a red swoosh at the bottom right. Inside the circle, the word "DIN" is written in blue, and below it, the word "Geprüft" is written in blue.



2021-08-26
Dipl.-Wi.-Ing. (FH) Sören Scholz
Head of Certification Body

S. Sg



ANNEX

Certificate STB1135S dated 2021-08-26

Technical Data Setpoint value ranges / limit value ranges:
610 AC3 94 °C - 12 K
610 AC3 98 °C - 12 K
610 AC3 100 °C - 12 K
600 AC2 98 °C - 12 K
650 Delta: 93 °C - 12 K

See technical data sheet to the above mentioned registration number at www.dincertco.tuv.com

**Testing laboratory/
Inspection body** TÜV Rheinland Industrie
Service GmbH
Am Grauen Stein
51105 Köln
GERMANY

Test report(s) T101 2008 T2 dated 2008-02-11
GA 11 2010 A7 dated 2010-02-19
21215416 dated 2010-11-17
21218754 dated 2012-01-31
21220772 dated 2012-12-03
T 101 2013 V4 dated 2013-10-08
21226519 dated 2014-11-17
21229240 dated 2015-11-23
T 101 2016 A5 dated 2016-11-21
T 101 2017 A6 dated 2017-11-16
968/FSP 1573.00/18 dated 2018-02-22
968/FI 1026.0018 dated 2019-01-10
968/FI 1026.01/19 dated 2019-12-05
968/FI 1026.02/20 dated 2020-10-27
968/FSP 1573.01/21 dated 2021-08-05

