



AGA CERTIFIED PRODUCT

Certificate Holder: **SIT GAS CONTROLS PTY LTD**

ABN/ACN No. (if applicable): **006 090 357**

Manufacturer: **SIT S.p.A.**

Agent (if applicable): **N/A**

Type of Component: **VALVE TYPE THERMOELECTRIC
FLAME SAFEGUARD**

Model No. & Description: **SIT**
(Refer www.aga.asn.au for more details) **440 D3 SERIES** **CLASS 3**

**0440005, 0440007, 0440013, 0440033 &
0440034**

Gas Connections: Rp 1/2" and Rp 3/4"
Rated Working Pressure: 5 kPa
Rated Temperature Range: 0°C to 80°C

Relevant Standard(s): **AS 4620 – 2004 (Including Amdt No. 1)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



Client Manager

Certificate Authorised

Certificate first issued: **17 May 1983**

Certificate No: **3530**

This copy valid from: **5 March 2018**

Refer specification issue: **06**

Directory Certificate Entry

Components

Thermoelectric Flame Safeguards

SIT Gas Controls Pty Ltd

(10 Treforest Drive, Clayton, 3168 VIC AUSTRALIA Ph: 03 9538 9900)

Relevant Standard/s:

AS 4620 | 2004 Amdt 1 | Thermoelectric flame safeguards | 21/12/2016

SIT

3530 5.83

SIT Class 3 Valve Type Thermoelectric Flame Safeguard

440 D3 Series

0440005, 0440007, 0440013, 0440033 & 0440034

kPa Rating

5

Gas Connections: Rp 1/2" and Rp 3/4"

Rated Temperature Range: 0°C to 80°C

Monday, 5 March 2018