



# AGA CERTIFIED PRODUCT

Certificate Holder: **SIT GAS CONTROLS PTY LTD**

ABN/ACN No. (if applicable): **006 090 357**

Manufacturer: **SIT S.p.A**

Agent (if applicable): **N/A**

Type of Component: **Combination Gas Control**

Model No. & Description: **SIT**  
*(Refer [www.aga.asn.au](http://www.aga.asn.au) for more details)* **630 Eurosit, 630 Eurosit Plus & 630 Eurosit 120°C**

Refer to Page 2 for models

Relevant Standard(s): **AS 4624 – 2005 (Inc. Amendment 1)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

**This Certificate is issued on the express conditions that:**

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



**Client Manager**

**Certificate Authorised**

Certificate first issued: **31 January 1984**

Certificate No: **3721**

This copy valid from: **7 August 2017**

Refer specification issue: **06**



# AGA CERTIFIED PRODUCT

Certificate Holder: **SIT GAS CONTROLS PTY LTD**

Model Designation :

**630 Eurosit :**

**0630001, 0630011, 0630012, 0630013, 0630014, 0630015, 0630017, 0630018, 0630019, 0630021, 0630022, 0630023, 0630024, 0630025, 0630026, 0630027, 0630029, 0630036, 0630037, 0630038, 0630039, 0630041, 0630043, 0630045, 0630046, 0630047, 0630052, 0630054, 0630057, 0630058, 0630061, 0630063, 0630064, 0630065, 0630066, 0630068, 0630093, 0630094, 0630095, 0630096, 0630097, 0630099, 0630100, 0630101, 0630102, 0630103, 0630104, 0630106, 0630107, 0630108, 0630151, 0630152, 0630153, 0630154, 0630155, 0630201, 0630203, 0630204, 0630205, 0630206, 0630325, 0630344, 0630500, 0630501, 0630503, 0630504, 0630505, 0630507, 0630508, 0630509, 0630513, 0630515, 0630516, 0630519, 0630522, 0630525, 0630530, 0630531, 0630534, 0630536, 0630540, 0630541, 0630542, 0630544, 0630545, 0630547, 0630548, 0630551, 0630555, 0630562, 0630563, 0630564, 0630566, 0630567, 0630568, 0630569, 0630801, 0630802, 0630803, 0630804 & 0630807**

**630 Eurosit Plus :**

**0630700, 0630703, 0630704, 0630705, 0630707, 0630708, 0630712 & 0630715**

**630 Eurosit 120°C :**

**0630305, 0630306, 0630307, 0630308, 0630309, 0630326, 0630327, 0630328, 0630330, 0630331, 0630332, 0630334, 0630335, 0630336, 0630337, 0630338, 0630339, 0630340, 0630343, 0630345, 0630346, 0630347, 0630348, 0630349 & 0630350**

	Rated working pressure (kPa)	Working temperature range (°C)	Outlet pressure range (kPa)	Magnet unit drop out – hold in current range (mA)	Thermostatic operating temperature range (°C)
<b>EUROSIT 630</b>	5	0 to 80	0.3 to 3.7	>40 <340	6 to 340
<b>EUROSIT 630 PLUS</b>	5	0 to 80	0.3 to 3.7	>40 <200	8 to 38
<b>EUROSIT 630 120 °C</b>	5	0 to 120	Not fitted	>40 <340	40 to 340

**Client Manager**

**Certificate Authorised**

Certificate first issued: **31 January 1984**

Certificate No: **3721**

This copy valid from: **7 August 2017**

Refer specification issue: **06**

# Directory Certificate Entry

## Components

### Combination Controls

SIT Gas Controls Pty Ltd

(10 Treforest Drive, Clayton, 3168 VIC AUSTRALIA Ph: 03 9538 9900)

Relevant Standard/s:

AS 4624 | 2005 Amdt 1 | Combination controls for gas | 21/12/2016

### SIT

3721 1.84

#### 630 Eurosit, 630 Eurosit Plus & 630 Eurosit 120°C Combination Control

kPa Rating

630 Eurosit :

5

0630001, 0630011, 0630012, 0630013, 0630014, 0630015, 0630017, 0630018,  
0630019, 0630021, 0630022, 0630023, 0630024, 0630025, 0630026, 0630027,  
0630029, 0630036, 0630037, 0630038, 0630039, 0630041, 0630043, 0630045,  
0630046, 0630047, 0630052, 0630054, 0630057, 0630058, 0630061, 0630063,  
0630064, 0630065, 0630066, 0630068, 0630093, 0630094, 0630095, 0630096,  
0630097, 0630099, 0630100, 0630101, 0630102, 0630103, 0630104, 0630106,  
0630107, 0630108, 0630151, 0630152, 0630153, 0630154, 0630155, 0630201,  
0630203, 0630204, 0630205, 0630206, 0630325, 0630344, 0630500, 0630501,  
0630503, 0630504, 0630505, 0630507, 0630508, 0630509, 0630513, 0630515,  
0630516, 0630519, 0630522, 0630525, 0630530, 0630531, 0630534, 0630536,  
0630540, 0630541, 0630542, 0630544, 0630545, 0630547, 0630548, 0630551,  
0630555, 0630562, 0630563, 0630564, 0630566, 0630567, 0630568, 0630569,  
0630801, 0630802, 0630803, 0630804 & 0630807

630 Eurosit Plus :

5

0630700, 0630703, 0630704, 0630705, 0630707, 0630708, 0630712 & 0630715

630 Eurosit 120°C :

5

0630305, 0630306, 0630307, 0630308, 0630309, 0630326, 0630327, 0630328,  
0630330, 0630331, 0630332, 0630334, 0630335, 0630336, 0630337, 0630338,  
0630339, 0630340, 0630343, 0630345, 0630346, 0630347, 0630348, 0630349 &  
0630350

Model	Eurosit 630	Eurosit 630 Plus	Eurosit 630 120°C
Rated Working Pressure (kPa)	5	5	5
Working Temperature Range (°C)	0 to 80	0 to 80	0 to 120
Outlet Pressure Range (kPa)	0.3 to 3.7	0.3 to 3.7	Not fitted
Magnet Unit Drop Out - Hold in Current Range (mA)	>40 <340	>40 <200	>40 <340
Thermostatic Operating Temperature Range (°C)	6 to 340	8 to 38	40 to 340

Monday, 28 August 2017