



# AGA CERTIFIED PRODUCT

Certificate Holder: **SIT GAS CONTROLS PTY LTD**

ABN/ACN No. (if applicable): **006 090 357**

Manufacturer: **SIT S.p.A.**

Agent (if applicable): **N/A**

Type of Component: **COMBINATION GAS CONTROL with GAS/AIR RATIO CONTROLLER**

Model No. & Description: **SIT 828 NOVAMIX**  
(Refer [www.aga.asn.au](http://www.aga.asn.au) for more details)

**0828101, 0828106, 0828108, 0828110, 0828111,  
0828112, 0828113, 0828115, 0828116, 0828118,  
0828119, 0828120, 0828121, 0828122, 0828304,  
0828307, 0828351, 0828403, 0828407 & 0828410**

*Rated Working Pressure:* 6 kPa  
*Working Temperature Range:* 0 to 60°C  
*Maximum Flow Rate:* 6.5m<sup>3</sup>/h (relative density = 0.6)

Automatic Shut-off Valves	Gas/Air Pressure Ratio	Regulator	Outlet Pressure
Class 2	3.5:1 to 20:1	Class 2 Grade 20	0.3 – 3.0 kPa 2.0 – 5.0 kPa

Relevant Standard(s): **AS 4624 – 2005 (Inc. Amendment 1)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

**This Certificate is issued on the express conditions that:**

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.

**Client Manager**

**Certificate Authorised**



Certificate first issued: **6 November 1976**

Certificate No: **5182**

This copy valid from: **8 August 2017**

Refer specification issue: **04**

# Directory Certificate Entry

## Components

### Combination Controls

SIT Gas Controls Pty Ltd

(10 Treforest Drive, Clayton, 3168 VIC AUSTRALIA Ph: 03 9538 9900)

Relevant Standard/s:

AS 4624 | 2005 Amdt 1 | Combination controls for gas | 21/12/2016

## SIT

5182 10.94

### 828 Novamix Combination Control

### kPa Rating

0828101, 0828106, 0828108, 0828110, 0828111, 0828112, 0828113, 0828115,  
0828116, 0828118, 0828119, 0828120, 0828121, 0828122, 0828304, 0828307,  
0828351, 0828403, 0828407 & 0828410

6

Outlet  
Pressure 0.3 to 3.0 2.0 to 5.0  
Range (kPa)

Automatics Shut-off Valves  
Class 2

Gas/Air Pressure Ratio 3.5:1 to 20:1

Regulator  
Class 2 Grade 20

Working Temperature Range: 0 to 60°C

Maximum Flow Rate: 6.5 m<sup>3</sup>/h (relative density = 0.6)

Monday, 28 August 2017