



Certificate of Compliance

Certificate: 1611792

Master Contract: 217676

Project: 1751088

Date Issued: 2006/01/27

Issued to: S.I.T. Controls B.V.
A.G. Bellstraat 2
Hoogeveen, 7902 AD
Netherlands
Attention: H. Wever

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: John Kory

Authorized by: Janusz Pankowski, Manager of Certification Services

PRODUCTS

CLASS 4813 82 - TEMPERATURE-INDICATING AND REGULATING EQUIPMENT -
Other than Appliance Type - Certified to US Standards

CLASS 4813 02 - TEMPERATURE-INDICATING AND REGULATING EQUIPMENT -
Other Than Appliance Type

Temperature regulating systems consisting of Zone Control and low voltage Interface Controller:

Model M-1025 rated 120 Vac, 60 HZ 1850 Watts maximum.

Control input - 120 Vac, 60 HZ, 50VA

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



Certificate: 1611792

Master Contract: 217676

Project: 1751088

Date Issued: 2006/01/27

Outputs:

4 @ 24 Vac, 0.25 A, for mixing valves

4 @ 120 Vac 3.5 A, pump motors

Model C-1125 rated 120 Vac, 60 HZ 1850 Watts maximum.

Control input - 120 Vac, 60 HZ, 50 VA

Outputs:

2 @ 120 Vac 3.5 A, pump motors

1 @ 120 Vac 3.5 A, fan motor

1 @ 120 Vac 3.5 A, additional boiler

This equipment is Certified as a component for use in other equipment where the suitability of the combination is determined in the end use by CSA and where the Zone Control is installed in a suitable enclosure.

60 degree C maximum ambient.

APPLICABLE REQUIREMENTS

C22.2 No. 24 - 93 Temperature Indicating and Regulating Equipment

UL 873 Temperature Indicating and Regulating Equipment, 11th edition