

UKCA Type Examination Certificate

This is to certify that:

SIT SPA
VIALE DELL'INDUSTRIA 31 33
Padova
35129
Italy

Holds Certificate Number:

UKCA 762897

In respect of:

Pressure sensing devices for gas burners and gas burning appliances as listed on page 2

Type samples representative of product(s) have been tested and examined according to the procedures specified in Annex III Module B (Type Examination) of The Product Safety and Metrology etc (Amendment etc)(EU Exit) Regulations 2020 (SI 2020/676) for the Regulation for Appliances burning gaseous fuels and found to comply with the Essential Requirements as detailed in Annex I of the Regulations.

For and on behalf of BSI, an Approved
Body for the above Regulation
(Approved Body Number 0086):

Frank Lee, Product Certification Technical and Compliance Director

First Issued: 2022-07-28

Latest Issue: 2022-07-28

Effective Date: 2022-07-28

Expiry Date: 2028-04-27

Page: 1 of 2

...making excellence a habit.™

UKCA Type Examination Certificate

No. UKCA 762897

Type Test Report Number: 17/260/4107/298

Project Number: Q583064 / BSI 945874

Model Designation	For Installation In	Normative Reference
310 Gas	GB	BS EN 1854: 2010

Application Warning: These devices may not be suitable for all applications and it is the responsibility of appliance designers to select the control devices that are appropriate for their specific product design.

First Issued: 2022-07-28

Latest Issue: 2022-07-28

Effective Date: 2022-07-28

Expiry Date: 2028-04-27

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.