


CERTIFICATE

Certificate holder	SIT S.p.a. Viale dell'Industria 31-33 35129 Padova PD ITALY
Product	Temperature control and limiting devices for heat generating systems
Type, Model	610 AC3
Testing basis	DIN EN 14597:2015-02 Certification scheme Temperature control and limiting devices for heat generating systems (2009-01)
Mark of conformity	
Registration No.	STB1135S
Valid until	2028-02-28
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

ANNEX

Page 1 of 1

Certificate	STB1135S dated 2023-06-01
Technical Data	Setpoint value ranges / limit value ranges: 610 AC3 94 °C - 12 K 610 AC3 98 °C - 12 K 610 AC3 100 °C - 12 K See technical data sheet to the above mentioned registration number at www.dincertco.tuv.com
Testing laboratory/ Inspection body	TÜV Rheinland Industrie Service GmbH Am Grauen Stein 51105 Köln GERMANY
Test report(s)	T101 2008 T2 dated 2008-02-11 GA 11 2010 A7 dated 2010-02-19 T 101 2013 V4 dated 2013-10-08 T 101 2016 A5 dated 2016-11-21 T 101 2017 A6 dated 2017-11-16 968/FSP 1573.00/18 dated 2018-02-22 968/FSP 1573.01/21 dated 2021-08-05 968/FSP 1573.02/23 dated 2023-03-20

