



# Certificate of Compliance

**Certificate:** 80182337

**Master Contract:** 189456

**Project:** 80182337

**Date Issued:** 2023-12-19

**Issued To:** SIT SPA  
Viale dell' Industria, 31-33  
Padova, Padova, 35129  
Italy

**Attention:** Nicola Lovison

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*

**Issued by:** Grace Gao  
Grace Gao



## **PRODUCTS**

CLASS - C263203 - FUEL BURNING EQUIPMENT (GAS) Gas Burners, Electrical Equipment for Accessories

CLASS - C263283 - FUEL BURNING EQUIPMENT(GAS)-Gas Burners Electrical Equipment for Accessories-Certified to U.S. Standards

Automatic burner control system, model 0.580.261

## **ELECTRICAL RATINGS**

Control voltage input: 120 Vac, 60 Hz, 20W

Main Gas Valve Output: 24Vac, 0.5A

Pump Output: 120Vac, 1.5A

Fan Output: 120Vac, 1.5A



**Certificate:** 80182337  
**Project:** 80182337

**Master Contract:** 189456  
**Date Issued:** 2023-12-19

Sparker: 120Vac, 1.5A

Operation ambient: 0C to 60C, 100,000 cycles

Note:

1. The subject controls are certified as components for use only inside other Certified equipment with suitable flame rated enclosure and transformer where the suitability of the combination is to be determined by a certification body i.e., CSA-Group.
2. The above, referenced models are provided with software Versions as confirmed in Appendix B software Report, Control Class C

**APPLICABLE REQUIREMENTS**

ANSI Z21.20-2014 • CAN/CSA C22.2 NO. 60730-2-5-14 - Automatic electrical controls for household and similar use - Part 2-5: Particular requirements for automatic electrical burner control systems (Bi-national standard with ANSI Z21.20-2014 and UL 60730-2-5)

Notes:

Products certified under Class C263203 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). [www.scc.ca](http://www.scc.ca)

