



AGA CERTIFIED PRODUCT

Certificate Holder: **SIT GAS CONTROLS PTY LTD**

ABN/ACN No. (if applicable): **006 090 357**

Manufacturer: **SIT LA PRECISA SRL**

Agent (if applicable): **N/A**

Type of Component: **CLASS 3 VALVE TYPE THERMOELECTRIC
FLAME SAFEGUARD**

Model No. & Description: **SIT
400 M1 HP**
(Refer www.aga.asn.au for more details)

Rated Working Pressure: 500 kPa
Rated Temperature Range: 0°C to 80 °C
(150 °C HT Versions)

Relevant Standard(s): **AS 4620 - 2004**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.




Reviewing Officer


Certificate Authorised

Certificate first issued: **17 May 1983**

Certificate No: **3532**

This copy valid from: **26 May 2015**

Refer specification issue: **04**

Directory Certificate Entry

Components

Thermoelectric Flame Safeguards

SIT Gas Controls Pty Ltd

(8 Pickering Road, MULGRAVE, 3170 VIC AUSTRALIA Ph: 03 9560 1444)

Relevant Standard/s:

AS 4620 | 2004 | Thermoelectric flame safeguards | 24/11/2004

SIT

3532 5.83

Class 3 Valve Type Thermoelectric Flame Safeguard
400 M1 HP

kPa Rating
500

Rated Temperature Range: 0°C to 80°C (150°C HT Versions)

Thursday, 28 May 2015